

# England - 22kV and 66kV network



Scale: 40821.0416601486  
 Plot Date 10/10/2022 19:07:04  
 UNCONTROLLED COPY  
 Subject to revision  
 Master held by SSEN Asset Data Team - Asset.Data@sse.com

- SSEN**
- Cable Segment EHV Route
    - 22 kV
    - 66 kV
  - Line Segment EHV Route
    - 22 kV
    - 66 kV
  - National Grid Electricity Cable
  - National Grid Electricity Line
  - Assigned Service Territory Company Event
  - Substation Loading Point
  - Substations

**VOLTAGES (V)**

LV (Low Voltage) and Services	up to 1,000V
HV (High Voltage)	over 1,000 to 11,000V
EHV (Extra High Voltage)	22,000V to 132,000V
Transmission	275,000V and 400,000V

**NORMAL DEPTH TO THE TOP OF CABLE WHEN LAID**

	Services	LV	HV	EHV
FOOTPATH/ UNMADE	0.45m	0.45m	0.60m	0.80m
ROAD CROSSING	0.60m	0.60m	0.75m	0.90m
AGRICULTURAL	1m	1m	1m	1m

**WARNING**

There may have been subsequent alterations to the surface levels. Trial holes must be taken to determine positions and depths of cables. HS (G) 47 Booklet from Health and Safety Executive - Avoiding Danger from Buried Cables - should be consulted before commencing excavation work. WHEN WORKING ON THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE G56 SHOULD BE CONSULTED (AVAILABLE FROM THE HSE WEBSITE)

If you are unsure & need to seek advise before commencing excavations please contact;

General Enquiries	01256 337 294
-------------------	---------------

BASED UPON THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF H.M. STATIONERY OFFICE. CROWN COPYRIGHT RESERVED.

This copy has been made by or with the authority of Southern Electric Power Distribution Ltd Pursuant to section 47 of the Copyright, Designs and Patents Act 1988 ('The Act'). Unless the Act provides a relevant exception to copyright, the copy must not be copied without the prior permission of the copyright owner.

Southern Electric Power Distribution Ltd.  
 Registered in England and Wales No.04094290  
 Registered Office: No. 1 Forbury Place, 43 Forbury Road Reading RG1 3JH

See LONGTERM PLAN/2022/1 For diagram with 33kV and 132kV Circuits